

Coonabarabran Water Supply - Chemistry Sample Test Results
(from the NSW Drinking Water Database)

Date Collected	Tested Parameters	Units	Test Results	Aesthetic Guideline	Health Guideline Value
17-03-2021	Aluminium	mg/L	0.0100	0.2	
17-03-2021	Antimony	mg/L	< 0.0001		0.003
17-03-2021	Arsenic	mg/L	< 0.001		0.01
17-03-2021	Barium	mg/L	0.0127		2
17-03-2021	Boron	mg/L	0.0074		4
17-03-2021	Cadmium	mg/L	< 0.0001		0.002
17-03-2021	Calcium	mg/L	17.8000		10000
17-03-2021	Chloride	mg/L	8.0000	250	
17-03-2021	Chromium	mg/L	< 0.001		0.05
17-03-2021	Copper	mg/L	0.0130	2	
17-03-2021	Fluoride	mg/L	< 0.1		1.5
17-03-2021	Iodine	mg/L	< 0.02		0.5
17-03-2021	Iron	mg/L	0.1700	0.3	
17-03-2021	Lead	mg/L	0.0002		0.01
17-03-2021	Magnesium	mg/L	1.8800		10000
17-03-2021	Manganese	mg/L	0.0064	0.5	
17-03-2021	Mercury	mg/L	< 0.0008		0.001
17-03-2021	Molybdenum	mg/L	0.0003		0.05
17-03-2021	Nickel	mg/L	< 0.0004		0.02
17-03-2021	Nitrate	mg/L	< 1		50
17-03-2021	Nitrite	mg/L	< 0.1		3
17-03-2021	pH		7.4000	6.5 - 8.5	
17-03-2021	Selenium	mg/L	< 0.007		0.01
17-03-2021	Silver	mg/L	< 0.0002		0.1
17-03-2021	Sodium	mg/L	7.0000	180	
17-03-2021	Sulfate	mg/L	37.0000	500	
17-03-2021	Total Dissolved Solids (TDS)	mg/L	77.0000	600	
17-03-2021	Total Hardness as CaCO ₃	mg/L	52.2000	200	
17-03-2021	True Colour	Hazen Units (HU)	< 1	15	
17-03-2021	Turbidity	NTU	3.7000	5	
17-03-2021	Uranium	mg/L	< 0.0001		0.017
17-03-2021	Zinc	mg/L	0.1000	3.0	