

**Dunedoo Water Supply - Chemistry Sample Test Results
(from the NSW Drinking Water Database)**

Date Collected	Tested Parameter	Units	Test Result	Aesthetic Guideline Value	Health Guideline Value
15-03-2022	Aluminium	mg/L	0.0100	0.2	
15-03-2022	Antimony	mg/L	< 0.0001		0.003
15-03-2022	Arsenic	mg/L	0.0020		0.01
15-03-2022	Barium	mg/L	0.0858		2
15-03-2022	Boron	mg/L	0.0627		4
15-03-2022	Cadmium	mg/L	< 0.0001		0.002
15-03-2022	Calcium	mg/L	68.6000		
15-03-2022	Chloride	mg/L	190.0000	250	
15-03-2022	Chromium	mg/L	0.0010		0.05
15-03-2022	Copper	mg/L	0.0080	1	2
15-03-2022	Fluoride	mg/L	0.5500		1.5
15-03-2022	Iodine	mg/L	0.0700		0.5
15-03-2022	Iron	mg/L	0.0300	0.3	
15-03-2022	Lead	mg/L	< 0.0002		0.01
15-03-2022	Magnesium	mg/L	56.1300		
15-03-2022	Manganese	mg/L	0.0023	0.1	0.5
15-03-2022	Mercury	mg/L	< 0.0008		0.001
15-03-2022	Molybdenum	mg/L	0.0017		0.05
15-03-2022	Nickel	mg/L	0.0004		0.02
15-03-2022	Nitrate	mg/L	2.0000		50
15-03-2022	Nitrite	mg/L	< 0.1		3
15-03-2022	pH		7.3000	6.5 - 8.7	
15-03-2022	Selenium	mg/L	0.0000		0.01
15-03-2022	Silver	mg/L	< 0.0002		0.1
15-03-2022	Sodium	mg/L	107.0000	180	
15-03-2022	Sulfate	mg/L	23.0000	250	500
15-03-2022	Total Dissolved Solids (TDS)	mg/L	694.0000	600	
15-03-2022	Total Hardness as CaCO ₃	mg/L	402.4000	200	
15-03-2022	True Colour	Hazen Units (HU)	< 1	15	
15-03-2022	Turbidity	NTU	0.3000	5	

15-03-2022	Uranium	mg/L	0.0010		0.017
15-03-2022	Zinc	mg/L	0.0300	3	