

### Kenebri Water Supply - Chemistry Sample Test Results (from the NSW Drinking Water Database)

Sample Collection Date	Tested Parameter	Unit	Test Result	Aesthetic Guideline Value	Health Guideline Value
12-09-2017	Aluminium	mg/L	0.01	0.2	
12-09-2017	Antimony	mg/L	< 0.001		0.003
12-09-2017	Arsenic	mg/L	0.002		0.01
12-09-2017	Barium	mg/L	0.263		2
12-09-2017	Boron	mg/L	0.1		4
12-09-2017	Cadmium	mg/L	< 0.0005		0.002
12-09-2017	Calcium	mg/L	12.3		
12-09-2017	Chloride	mg/L	187	250	
12-09-2017	Chromium	mg/L	< 0.005		0.05
12-09-2017	Copper	mg/L	0.008	1	2
12-09-2017	Fluoride	mg/L	0.25		1.5
12-09-2017	Iodine	mg/L	0.02		0.5
12-09-2017	Iron	mg/L	0.02	0.3	
12-09-2017	Lead	mg/L	< 0.002		0.01
12-09-2017	Magnesium	mg/L	8.73		
12-09-2017	Manganese	mg/L	< 0.005	0.1	0.5
12-09-2017	Mercury	mg/L	< 0.0001		0.001
12-09-2017	Molybdenum	mg/L	< 0.005		0.05
12-09-2017	Nickel	mg/L	< 0.01		0.02
12-09-2017	Nitrate	mg/L	1.7		50
12-09-2017	Nitrite	mg/L	< 0.1		3
12-09-2017	pH		6.9	6.5 - 8.7	
12-09-2017	Selenium	mg/L	< 0.002		0.01
12-09-2017	Silver	mg/L	< 0.002		0.1
12-09-2017	Sodium	mg/L	146	180	
12-09-2017	Sulfate	mg/L	11	250	500
12-09-2017	Total Dissolved Solids (TDS)	mg/L	494	600	
12-09-2017	Total Hardness as CaCO <sub>3</sub>	mg/L	66.7	200	
12-09-2017	True Colour	Hazen Units (HU)	< 1	15	
12-09-2017	Turbidity	NTU	< 0.1	5	
12-09-2017	Uranium	mg/L	< 0.005		0.017
12-09-2017	Zinc	mg/L	0.05	3	