Bugaldie Water Supply - Microbiological Test Results (from the NSW Drinking Water Database)

| Sample Collection Date | Tested Parameter | Unit | Test Result | Australian Drinking Water Guidelines Value | Laboratory Comments |
|---|---|---|---|---|---|
| 13-03-2018 | E. coli | cfu/100 mL | < 1 | 0 | |
| 13-03-2018 | Free Chlorine | mg/L | 1.5800 | 0.2 - 5 | |
| 13-03-2018 | Total Coliforms | cfu/100 mL | < 1 | 0 | |
| 17-04-2018 | E. coli | cfu/100 mL | < 1 | 0 | |
| 17-04-2018 | Total Coliforms | cfu/100 mL | < 1 | 0 | |
| 15-05-2018 | E. coli | cfu/100 mL | < 1 | 0 | |
| 15-05-2018 | Free Chlorine | mg/L | 2.5100 | 0.2 - 5 | |
| 15-05-2018 | Total Coliforms | cfu/100 mL | < 1 | 0 | |
| 13-06-2018 | E. coli | cfu/100 mL | < 1 | 0 | ,Field result entered as provided |
| 13-06-2018 | Total Coliforms | cfu/100 mL | < 1 | 0 | ,Field result entered as provided |
| 16-07-2018 | E. coli | cfu/100 mL | < 1 | 0 | |
| 16-07-2018 | Free Chlorine | mg/L | 3.5100 | 0.2 - 5 | |
| 16-07-2018 | Total Coliforms | cfu/100 mL | < 1 | 0 | |
| 14-08-2018 | E. coli | cfu/100 mL | < 1 | 0 | |
| 14-08-2018 | Free Chlorine | mg/L | 4.1500 | 0.2 - 5 | |
| 14-08-2018 | Total Coliforms | cfu/100 mL | < 1 | 0 | |