

Mr Kevin Tighe  
Doc ID: 61868

31 August 2016

Coinda Coonabarabran Limited  
12-14 Neate Street  
COONABARABRAN NSW 2357

Dear Sir/Madam

**Re: Trade Waste Inspection – 12-14 Neate Street, Coonabarabran  
trading as Coinda Residential Aged Care – Assessment: 10045417**

An inspection of the above property was undertaken by representatives of Warrumbungle Shire Council on **28 July 2016** to assess the premises in regards to liquid trade waste and the Liquid Trade Waste Approval to Discharge.

While the business does comply in part with the Approval conditions, further works are required as outlined below for your property to fully comply with Council's Policy and State Guidelines for trade waste. These works are to be completed by 31 August 2017.

- Installation of **Sink Screens** in all food preparation and handling areas.
- Installation of a **Grease Arrestor** (1000 L minimum capacity) to service the main kitchen.
- Installation of a **Grease Arrestor** (1000 L minimum capacity or equivalent) to service the Hostel kitchen.
- **Chemical and oil storage** containers are to be contained in a roofed and bunded area with either the bund having the capacity to retain 110% of the largest container or other acceptable means of containment that prevents flow to the sewerage system/environment in case of accident, leakage or spills.

Please note, non-compliance trade waste charges will be applicable until all works are completed and Council is satisfied the Approval conditions are met.

Evidence of completion of works (for example photographs, receipts of installations etc.) by the due date is required and may be forwarded to Council via email, mail or in person. A re-inspection fee (\$85.00 for 2016/17) may also be applicable if Council is required to undertake additional inspections to ensure works are complete.

A leaflet of Frequently Asked Questions has also been attached for your information.

Should you require any further information on trade waste requirements please contact Council's Manager Warrumbungle Water, Ms Cornelia Wiebels on 6849 2000.

Yours faithfully

**KEVIN TIGHE**  
**DIRECTOR TECHNICAL SERVICES**

*Attach: Frequently Asked Questions*