

Coonabarabran:

14-22 John Street
Coonabarabran NSW 2357

PO Box 191
Coonabarabran NSW 2357

ABN: 63 348 671 239



Calls from within Shire
1300 795 099

Calls from outside Shire area
Coonabarabran:
02 6849 2000

Coolah: 02 6378 5000

Fax: 02 6842 1337

Email:
info@warrumbungle.nsw.gov.au

Coonabarabran - Coolah - Dunedoo - Baradine - Binnaway - Mendooran

Please address all mail to: **John Boyle**
The General Manager **Doc ID:**

Please refer enquiries to:

18 January 2022

Coinda Coonabarabran Limited
12-14 Neate Street
COONABARABRAN NSW 2357

Dear Sir/Madam

**Re: Trade Waste Inspection – 12-14 Neate Street, Coonabarabran
trading as Coinda Residential Aged Care – Assessment: 10045417**

An inspection of the above property was undertaken by representatives of Warrumbungle Shire Council on **30 September 2021** to assess the premises in regards to liquid trade waste and the Liquid Trade Waste Approval to Discharge.

While the business does comply in part with the Approval conditions, further works are required as outlined below for your property to fully comply with Council's Policy and State Guidelines for trade waste. These works are to be completed by 28 February 2022.

- Installation of **Sink Screens** in all food preparation and handling areas.
- Installation of a **Grease Arrestor** (1000 L minimum capacity) to service all kitchens. (currently undersized)
- Installation of **Dry Baskets** to flooring screens.
- Disconnect **Pan Macerators**.
- **Chemical and oil storage** containers are to be contained in a roofed and bunded area with either the bund having the capacity to retain 110% of the largest container or other acceptable means of containment that prevents flow to the sewerage system/environment in case of accident, leakage or spills.


Please note, non-compliance trade waste charges will be applicable until all works are completed and Council is satisfied the Approval conditions are met.

Please see attached previous inspections and letters that note of non-compliance.

Evidence of completion of works (for example photographs, receipts of installations etc.) by the due date is required and may be forwarded to Council via email, mail or in person. A re-inspection fee (\$95.00 for 2021/22) may also be applicable if Council is required to undertake additional inspections to ensure works are complete.

Should you require any further information on trade waste requirements please contact Council's Water Technical Officer, Ms Danielle Tuckwell on 63 785 000.

Yours faithfully

A handwritten signature in black ink, appearing to read 'John Boyle', written in a cursive style.

JOHN BOYLE
ACTING MANAGER WARRUMBUNGLE WATER