


Trade Waste Inspection Report

Business Name	Cooinda Residential Aged Care	Authority ID.	10045417		
Address	100 Cassilis Street				
Date of Inspection	28/7/2016				
Activity	Nursing Home				
Classification	A	Charging category	2		
Approval	Yes				
Operation Details	<p><u>Main kitchen</u> - Renovations to be completed by June 2018. Includes installation of above ground grease arrestor outside main kitchen.</p> <p><u>Hostel</u> – Kitchen to be connected to new grease arrestor. Type and location to be determined. Wash up sink then rinse in dishwasher (plumber estimates 250L/day discharged to sewer)</p> <p><u>Chemical Store</u> – 2 floor wastes at front of chemical store. Area not banded to prevent spills/leaks flowing to sewer.</p> <p><u>Laundry</u> – Cold wash only; to confirm installation of lint filters when serviced externally</p>				
Estimated Volume Trade Waste	0.59 kL/d	TWDF (Estimated)	2 meters (to determine which is connected kitchen) #10614 – 5% #718019 – 30%	TWDF (Guidelines)	N/A
Pretreatment	Grease arrestor (Meryula), sink screens				
Requirements for Compliance	Grease arrestors, sink screens, bund chemical store				
Comments/Photos	<p>Chemical store (not banded) with floor wastes open to spills/leaks</p> 				
Hostel kitchen to be connected to grease arrestor	