

CERTIFICATE OF ANALYSIS

Work Order : **WN2303016**
Client : **WARRUMBUNGLE SHIRE COUNCIL**
Contact
Address : 59 Binnia Street
 COOLAH NSW 2843
Telephone : ----
Project : Coonabarabran STP - EPL 1744
Order number : ----
C-O-C number : ----
Sampler
Site : ----
Quote number : BLANKET QUOTE
No. of samples received : 1
No. of samples analysed : 1

Page : 1 of 2
Laboratory : ALS Water - Newcastle
Contact : Andrea Swan
Address : 5/585 Maitland Road Newcastle West NSW Australia 2304
Telephone : +61 2 4014 2500
Date Samples Received : 08-Mar-2023 09:30
Date Analysis Commenced : 08-Mar-2023
Issue Date : 15-Mar-2023 15:14



Accreditation No. 825
 Accredited for compliance with
 ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Allan Brown	Laboratory Technician	Chemistry, Newcastle West, NSW
Gregory Towers	Technical Officer	Chemistry, Newcastle West, NSW
Ruby Buller	Laboratory Technician	Chemistry, Newcastle West, NSW



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
 LOR = Limit of reporting
 ^ = This result is computed from individual analyte detections at or above the level of reporting
 ø = ALS is not NATA accredited for these tests.
 ~ = Indicates an estimated value.

Analytical Results

Sub-Matrix: **WATER**
 (Matrix: **WATER**)

Sample ID

				Effluent Coonabarabran point 2	----	----	----	----
Sampling date / time				07-Mar-2023 13:30	----	----	----	----
Compound	CAS Number	LOR	Unit	WN2303016-001	-----	-----	-----	-----
				Result	----	----	----	----
EA005: pH								
pH Value	----	0.01	pH Unit	7.32	----	----	----	----
EA025: Total Suspended Solids dried at 104 ± 2°C								
Suspended Solids (SS)	----	5	mg/L	<5	----	----	----	----
EK062A: Total Nitrogen as N								
Total Nitrogen as N	----	0.1	mg/L	5.9	----	----	----	----
EK067A: Total Phosphorus as P								
Total Phosphorus as P	----	0.05	mg/L	6.61	----	----	----	----
EP021: Total Oil and Grease								
Total Oil and Grease	----	2	mg/L	<2	----	----	----	----
EP030.WN: Biochemical Oxygen Demand (BOD)								
Biochemical Oxygen Demand	----	2	mg/L	7	----	----	----	----