

CERTIFICATE OF ANALYSIS

Work Order : WN2311057

Contact

Client

Address

C-O-C number

: WARRUMBUNGLE SHIRE COUNCIL Laboratory : ALS Water - Newcastle

Contact : 59 Binnia Street

COOLAH NSW 2843

Telephone

Project : Dunedoo STP - EPL 1747

Order number : 36340

Sampler Site

Quote number : EN/333

No. of samples received : 2 No. of samples analysed : 2 Page : 1 of 3

: Andrea Swan

Address : 5/585 Maitland Road Newcastle West NSW Australia 2304

Telephone : +61 2 4014 2500

Date Samples Received : 13-Sep-2023 08:50

Date Analysis Commenced : 13-Sep-2023

Issue Date : 19-Sep-2023 10:33



This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with **Quality Review and Sample Receipt Notification.**

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories	Position	Accreditation Category
Allan Brown	Laboratory Technician	Chemistry, Newcastle West, NSW
Andrea Hropot	Technical Assistant	Microbiology, Newcastle West, NSW
Christopher Cameron	Laboratory Technician	Chemistry, Newcastle West, NSW

Page : 2 of 3
Work Order : WN2311057

Client : WARRUMBUNGLE SHIRE COUNCIL

Project : Dunedoo STP - EPL 1747

General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key: CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.

LOR = Limit of reporting

- ^ = This result is computed from individual analyte detections at or above the level of reporting
- ø = ALS is not NATA accredited for these tests.
- ~ = Indicates an estimated value.
- Microbiological Comment: In accordance with ALS work instruction QWI-MIC/04, membrane filtration result is reported an approximate (~) when the count of colonies on the filtered membrane is outside the range of 10 100cfu
- MW006 is ALS's internal code and is equivalent to AS4276.5.
- CFU = colony forming unit
- MF = membrane filtration



Page : 3 of 3 Work Order : WN2311057

Client : WARRUMBUNGLE SHIRE COUNCIL

Project : Dunedoo STP - EPL 1747

Analytical Results



