

CERTIFICATE OF ANALYSIS

Work Order	: WN2303992	Page	: 1 of 3
Client	: WARRUMBUNGLE SHIRE COUNCIL	Laboratory	: ALS Water - Newcastle
Contact		Contact	: Andrea Swan
Address	: 59 Binnia St,	Address	: 5/585 Maitland Road Newcastle West NSW Australia 2304
	COOLAH NSW		
Telephone	:	Telephone	: +61 2 4014 2500
Project	: Dunedoo STP - EPL 1747	Date Samples Received	: 29-Mar-2023 09:50
Order number	:	Date Analysis Commenced	: 29-Mar-2023
C-O-C number	·	Issue Date	: 05-Apr-2023 15:55
Sampler			IC-MRA NATA
Site			
Quote number	: EN/333		Accreditation No. 825
No. of samples received	: 1		Accredited for compliance with
No. of samples analysed	: 1		ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories	Position	Accreditation Category		
Allan Brown	Laboratory Technician	Chemistry, Newcastle West, NSW		
Andrea Hropot	Technical Assistant	Microbiology, Newcastle West, NSW		
Christopher Cameron	Laboratory Technician	Chemistry, Newcastle West, NSW		
Gregory Towers	Technical Officer	Chemistry, Newcastle West, NSW		



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key: CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.

LOR = Limit of reporting

^ = This result is computed from individual analyte detections at or above the level of reporting

ø = ALS is not NATA accredited for these tests.

 \sim = Indicates an estimated value.

- Microbiological Comment: In accordance with ALS work instruction QWI-MIC/04, membrane filtration result is reported an approximate (~) when the count of colonies on the filtered membrane is outside the range
 of 10 100cfu.
- MW006 is ALS's internal code and is equivalent to AS4276.5.
- CFU = colony forming unit
- MF = membrane filtration



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)			Sample ID	Effluent Dunedoo point 1				
Sampling date / time			28-Mar-2023 00:00					
Compound	CAS Number	LOR	Unit	WN2303992-001				
				Result				
EA005: pH								
pH Value		0.01	pH Unit	8.21				
EA025: Total Suspended Solids dried at 104 ± 2°C								
Suspended Solids (SS)		1	mg/L	162				
EK055A: Ammonia as N								
Ammonia as N	7664-41-7	0.05	mg/L	9.12				
EK062A: Total Nitrogen as N								
Total Nitrogen as N		0.1	mg/L	57.6				
EK067A: Total Phosphorus as P								
Total Phosphorus as P		0.05	mg/L	7.14				
EP021: Total Oil and Grease								
Total Oil and Grease		2	mg/L	10				
EP030.WN: Biochemical Oxygen Demand (BOD)								
Biochemical Oxygen Demand		2	mg/L	45				
MW006: Faecal Coliforms & E.coli by MF								
Faecal Coliforms		1	CFU/100mL	40000				