

Bugaldie Water Supply - Microbiological Test Results
(from the NSW Drinking Water Database)

| Sample Collection Date | Tested Parameter | Units | Test Result | ADWG Guideline Values Health | ADWG Guideline Values Aesthetic | Labratory Comments |
|------------------------|------------------|------------|-------------|------------------------------|---------------------------------|-----------------------------------|
| 12/06/2024 | pH | | 7.2400 | | 6.5 - 8.5 | |
| 12/06/2024 | Free Chlorine | mg/L | 2.0800 | 0.2 - 5 | | |
| 12/06/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 12/06/2024 | Temperature | C | 13.5000 | | 30 | |
| 12/06/2024 | Turbidity | NTU | 0.3400 | | 5 | |
| 12/06/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 12/06/2024 | Total Chlorine | mg/L | 2.1500 | | 5 | |
| 1/05/2024 | pH | | 7.5500 | | 6.5 - 8.5 | ,Field result entered as provided |
| 1/05/2024 | Free Chlorine | mg/L | 1.2900 | 0.2 - 5 | | ,Field result entered as provided |
| 1/05/2024 | E. coli | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 1/05/2024 | Temperature | C | 18.7000 | | 30 | ,Field result entered as provided |
| 1/05/2024 | Turbidity | NTU | 2.1700 | | 5 | ,Field result entered as provided |
| 1/05/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 1/05/2024 | Total Chlorine | mg/L | 1.2500 | | 5 | ,Field result entered as provided |
| 2/04/2024 | pH | | 7.3800 | | 6.5 - 8.5 | |
| 2/04/2024 | Free Chlorine | mg/L | 2.1400 | 0.2 - 5 | | |
| 2/04/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 2/04/2024 | Temperature | C | 26.5000 | | 30 | |
| 2/04/2024 | Turbidity | NTU | 1.0000 | | 5 | |
| 2/04/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 2/04/2024 | Total Chlorine | mg/L | 2.3900 | | 5 | |
| 5/03/2024 | pH | | 7.1700 | | 6.5 - 8.5 | |
| 5/03/2024 | Free Chlorine | mg/L | 1.9200 | 0.2 - 5 | | |
| 5/03/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 5/03/2024 | Temperature | C | 28.1000 | | 30 | |
| 5/03/2024 | Turbidity | NTU | 0.5500 | | 5 | |
| 5/03/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 5/03/2024 | Total Chlorine | mg/L | 1.9800 | | 5 | |
| 7/02/2024 | pH | | 7.1800 | | 6.5 - 8.5 | |
| 7/02/2024 | Free Chlorine | mg/L | 1.3000 | 0.2 - 5 | | |
| 7/02/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 7/02/2024 | Temperature | C | 27.3000 | | 30 | |
| 7/02/2024 | Turbidity | NTU | 0.3600 | | 5 | |
| 7/02/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 7/02/2024 | Total Chlorine | mg/L | 1.3300 | | 5 | |
| 9/01/2024 | pH | | 7.5100 | | 6.5 - 8.5 | |
| 9/01/2024 | Free Chlorine | mg/L | 0.7300 | 0.2 - 5 | | |
| 9/01/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 9/01/2024 | Temperature | C | 25.3000 | | 30 | |
| 9/01/2024 | Turbidity | NTU | 0.7700 | | 5 | |
| 9/01/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 9/01/2024 | Total Chlorine | mg/L | 0.8000 | | 5 | |