

Coolah Water Supply - Microbiological Test Results
(from the NSW Drinking Water Database)

Sample Collection Date	Tested Parameter	Units	Test Result	ADWG Guideline Values Health	ADWG Guideline Values Aesthetic	Labratory Comments
24/06/2024	pH		8.1000		6.5 - 8.5	
24/06/2024	Free Chlorine	mg/L	0.6200	0.2 - 5		
24/06/2024	E. coli	mpn/100 mL	< 1	0		
24/06/2024	Temperature	C	16.2000		30	
24/06/2024	Turbidity	NTU	0.1100		5	
24/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
24/06/2024	Total Chlorine	mg/L	1.4000		5	
17/06/2024	pH		8.1100		6.5 - 8.5	
17/06/2024	Free Chlorine	mg/L	1.4500	0.2 - 5		
17/06/2024	E. coli	mpn/100 mL	< 1	0		
17/06/2024	Temperature	C	16.1000		30	
17/06/2024	Turbidity	NTU	0.0500		5	
17/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
17/06/2024	Total Chlorine	mg/L	1.5400		5	
11/06/2024	pH		8.0500		6.5 - 8.5	
11/06/2024	Free Chlorine	mg/L	0.9000	0.2 - 5		
11/06/2024	E. coli	mpn/100 mL	< 1	0		
11/06/2024	Temperature	C	14.2000		30	
11/06/2024	Turbidity	NTU	0.0000		5	
11/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
11/06/2024	Total Chlorine	mg/L	1.1200		5	
5/06/2024	pH		8.1000		6.5 - 8.5	
5/06/2024	Free Chlorine	mg/L	1.2000	0.2 - 5		
5/06/2024	E. coli	mpn/100 mL	< 1	0		
5/06/2024	Temperature	C	15.5000		30	
5/06/2024	Turbidity	NTU	0.0000		5	
5/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
5/06/2024	Total Chlorine	mg/L	1.3000		5	
28/05/2024	pH		8.0100		6.5 - 8.5	
28/05/2024	Free Chlorine	mg/L	0.6700	0.2 - 5		
28/05/2024	E. coli	mpn/100 mL	< 1	0		
28/05/2024	Temperature	C	15.6000		30	
28/05/2024	Turbidity	NTU	0.0200		5	
28/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
28/05/2024	Total Chlorine	mg/L	1.1500		5	
20/05/2024	pH		7.3300		6.5 - 8.5	
20/05/2024	Free Chlorine	mg/L	1.2600	0.2 - 5		
20/05/2024	E. coli	mpn/100 mL	< 1	0		
20/05/2024	Temperature	C	17.4000		30	
20/05/2024	Turbidity	NTU	0.0100		5	
20/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
20/05/2024	Total Chlorine	mg/L	1.4700		5	
15/05/2024	pH		7.2800		6.5 - 8.5	
15/05/2024	Free Chlorine	mg/L	1.1400	0.2 - 5		
15/05/2024	E. coli	mpn/100 mL	< 1	0		
15/05/2024	Temperature	C	20.5000		30	
15/05/2024	Turbidity	NTU	0.0900		5	
15/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
15/05/2024	Total Chlorine	mg/L	1.3200		5	
8/05/2024	pH		7.2700		6.5 - 8.5	
8/05/2024	Free Chlorine	mg/L	1.3800	0.2 - 5		
8/05/2024	E. coli	mpn/100 mL	< 1	0		
8/05/2024	Temperature	C	19.5000		30	
8/05/2024	Turbidity	NTU	0.1000		5	
8/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
8/05/2024	Total Chlorine	mg/L	1.4500		5	
29/04/2024	pH		7.8600		6.5 - 8.5	
29/04/2024	Free Chlorine	mg/L	1.0500	0.2 - 5		
29/04/2024	E. coli	mpn/100 mL	< 1	0		
29/04/2024	Temperature	C	22.0000		30	
29/04/2024	Turbidity	NTU	0.0100		5	
29/04/2024	Total Coliforms	mpn/100 mL	< 1	0		
29/04/2024	Total Chlorine	mg/L	1.1100		5	
22/04/2024	pH		7.7900		6.5 - 8.5	
22/04/2024	Free Chlorine	mg/L	1.4500	0.2 - 5		

22/04/2024	E. coli	mpn/100 mL	< 1	0		
22/04/2024	Temperature	C	21.3000		30	
22/04/2024	Turbidity	NTU	0.0500		5	
22/04/2024	Total Coliforms	mpn/100 mL	< 1	0		
22/04/2024	Total Chlorine	mg/L	1.4800		5	
17/04/2024	pH		8.1200		6.5 - 8.5	
17/04/2024	Free Chlorine	mg/L	1.4900	0.2 - 5		
17/04/2024	E. coli	mpn/100 mL	< 1	0		
17/04/2024	Temperature	C	20.5000		30	
17/04/2024	Turbidity	NTU	0.0000		5	
17/04/2024	Total Coliforms	mpn/100 mL	< 1	0		
17/04/2024	Total Chlorine	mg/L	1.5500		5	
8/04/2024	pH		8.1300		6.5 - 8.5	,Field result entered as provided
8/04/2024	Free Chlorine	mg/L	0.8000	0.2 - 5		,Field result entered as provided
8/04/2024	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
8/04/2024	Temperature	C	24.5000		30	,Field result entered as provided
8/04/2024	Turbidity	NTU	0.0500		5	,Field result entered as provided
8/04/2024	Total Coliforms	mpn/100 mL	< 1	0		,Field result entered as provided
8/04/2024	Total Chlorine	mg/L	0.7000		5	,Field result entered as provided
3/04/2024	pH		7.9700		6.5 - 8.5	
3/04/2024	Free Chlorine	mg/L	1.3300	0.2 - 5		
3/04/2024	E. coli	mpn/100 mL	< 1	0		
3/04/2024	Temperature	C	21.7000		30	
3/04/2024	Turbidity	NTU	0.0000		5	
3/04/2024	Total Coliforms	mpn/100 mL	< 1	0		
3/04/2024	Total Chlorine	mg/L	1.4100		5	
26/03/2024	pH		8.0400		6.5 - 8.5	
26/03/2024	Free Chlorine	mg/L	1.3600	0.2 - 5		
26/03/2024	E. coli	mpn/100 mL	< 1	0		
26/03/2024	Temperature	C	22.3000		30	
26/03/2024	Turbidity	NTU	0.0300		5	
26/03/2024	Total Coliforms	mpn/100 mL	< 1	0		
26/03/2024	Total Chlorine	mg/L	1.5000		5	
18/03/2024	pH		7.9700		6.5 - 8.5	,Sample contains ice
18/03/2024	Free Chlorine	mg/L	1.1900	0.2 - 5		,Sample contains ice
18/03/2024	E. coli	mpn/100 mL	< 1	0		,Sample contains ice
18/03/2024	Temperature	C	23.1000		30	,Sample contains ice
18/03/2024	Turbidity	NTU	0.0900		5	,Sample contains ice
18/03/2024	Total Coliforms	mpn/100 mL	< 1	0		,Sample contains ice
18/03/2024	Total Chlorine	mg/L	1.3500		5	,Sample contains ice
11/03/2024	pH		8.1500		6.5 - 8.5	
11/03/2024	Free Chlorine	mg/L	1.1900	0.2 - 5		
11/03/2024	E. coli	mpn/100 mL	< 1	0		
11/03/2024	Temperature	C	29.9000		30	
11/03/2024	Turbidity	NTU	0.0000		5	
11/03/2024	Total Coliforms	mpn/100 mL	< 1	0		
11/03/2024	Total Chlorine	mg/L	1.2000		5	
4/03/2024	pH		7.8800		6.5 - 8.5	
4/03/2024	Free Chlorine	mg/L	1.1100	0.2 - 5		
4/03/2024	E. coli	mpn/100 mL	< 1	0		
4/03/2024	Temperature	C	21.0000		30	
4/03/2024	Turbidity	NTU	0.3000		5	
4/03/2024	Total Coliforms	mpn/100 mL	< 1	0		
4/03/2024	Total Chlorine	mg/L	1.2000		5	
26/02/2024	pH		7.8600		6.5 - 8.5	
26/02/2024	Free Chlorine	mg/L	1.0800	0.2 - 5		
26/02/2024	E. coli	mpn/100 mL	< 1	0		
26/02/2024	Temperature	C	26.0000		30	
26/02/2024	Turbidity	NTU	0.6100		5	
26/02/2024	Total Coliforms	mpn/100 mL	< 1	0		
26/02/2024	Total Chlorine	mg/L	1.2100		5	
19/02/2024	pH		7.6800		6.5 - 8.5	
19/02/2024	Free Chlorine	mg/L	0.9400	0.2 - 5		
19/02/2024	E. coli	mpn/100 mL	< 1	0		
19/02/2024	Temperature	C	27.5000		30	
19/02/2024	Turbidity	NTU	0.0700		5	
19/02/2024	Total Coliforms	mpn/100 mL	< 1	0		
19/02/2024	Total Chlorine	mg/L	0.9700		5	
12/02/2024	pH		7.7700		6.5 - 8.5	

12/02/2024	Free Chlorine	mg/L	0.4700	0.2 - 5	
12/02/2024	E. coli	mpn/100 mL	< 1	0	
12/02/2024	Temperature	C	29.2000		30
12/02/2024	Turbidity	NTU	0.0700		5
12/02/2024	Total Coliforms	mpn/100 mL	< 1	0	
12/02/2024	Total Chlorine	mg/L	0.8700		5
5/02/2024	pH		7.6500		6.5 - 8.5
5/02/2024	Free Chlorine	mg/L	1.4600	0.2 - 5	
5/02/2024	E. coli	mpn/100 mL	< 1	0	
5/02/2024	Temperature	C	21.1000		30
5/02/2024	Turbidity	NTU	0.2200		5
5/02/2024	Total Coliforms	mpn/100 mL	< 1	0	
5/02/2024	Total Chlorine	mg/L	1.4800		5
29/01/2024	pH		7.8200		6.5 - 8.5
29/01/2024	Free Chlorine	mg/L	0.9700	0.2 - 5	
29/01/2024	E. coli	mpn/100 mL	< 1	0	
29/01/2024	Temperature	C	28.6000		30
29/01/2024	Turbidity	NTU	0.2600		5
29/01/2024	Total Coliforms	mpn/100 mL	< 1	0	
29/01/2024	Total Chlorine	mg/L	1.1100		5
22/01/2024	pH		7.7400		6.5 - 8.5
22/01/2024	Free Chlorine	mg/L	1.1500	0.2 - 5	
22/01/2024	E. coli	mpn/100 mL	< 1	0	
22/01/2024	Temperature	C	27.5000		30
22/01/2024	Turbidity	NTU	1.6100		5
22/01/2024	Total Coliforms	mpn/100 mL	< 1	0	
22/01/2024	Total Chlorine	mg/L	1.2200		5
15/01/2024	pH		7.8000		6.5 - 8.5
15/01/2024	Free Chlorine	mg/L	1.2700	0.2 - 5	
15/01/2024	E. coli	mpn/100 mL	< 1	0	
15/01/2024	Temperature	C	21.3000		30
15/01/2024	Turbidity	NTU	0.0500		5
15/01/2024	Total Coliforms	mpn/100 mL	< 1	0	
15/01/2024	Total Chlorine	mg/L	1.3000		5
8/01/2024	pH		8.1400		6.5 - 8.5
8/01/2024	Free Chlorine	mg/L	1.0100	0.2 - 5	
8/01/2024	E. coli	mpn/100 mL	< 1	0	
8/01/2024	Temperature	C	29.8000		30
8/01/2024	Turbidity	NTU	0.3800		5
8/01/2024	Total Coliforms	mpn/100 mL	< 1	0	
8/01/2024	Total Chlorine	mg/L	1.0100		5
2/01/2024	pH		8.0900		6.5 - 8.5
2/01/2024	Free Chlorine	mg/L	0.7300	0.2 - 5	
2/01/2024	E. coli	mpn/100 mL	< 1	0	
2/01/2024	Temperature	C	25.6000		30
2/01/2024	Turbidity	NTU	0.2300		5
2/01/2024	Total Coliforms	mpn/100 mL	< 1	0	
2/01/2024	Total Chlorine	mg/L	0.8600		5