

Dunedoo Water Supply - Microbiological Test Results
(from the NSW Drinking Water Database)

| Sample Collection Date | Tested Parameter | Units | Test Result | ADWG Guideline Values Health | ADWG Guideline Values Aesthetic | Labratory Comments |
|------------------------|------------------|------------|-------------|------------------------------|---------------------------------|-----------------------------------|
| 24/06/2024 | pH | | 8.1000 | | 6.5 - 8.5 | |
| 24/06/2024 | Free Chlorine | mg/L | 1.5100 | 0.2 - 5 | | |
| 24/06/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 24/06/2024 | Temperature | C | 16.6000 | | 30 | |
| 24/06/2024 | Turbidity | NTU | 0.1200 | | 5 | |
| 24/06/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 24/06/2024 | Total Chlorine | mg/L | 1.5500 | | 5 | |
| 17/06/2024 | pH | | 8.0400 | | 6.5 - 8.5 | |
| 17/06/2024 | Free Chlorine | mg/L | 1.5100 | 0.2 - 5 | | |
| 17/06/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 17/06/2024 | Temperature | C | 14.7000 | | 30 | |
| 17/06/2024 | Turbidity | NTU | 0.0700 | | 5 | |
| 17/06/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 17/06/2024 | Total Chlorine | mg/L | 1.5400 | | 5 | |
| 11/06/2024 | pH | | 8.1000 | | 6.5 - 8.5 | |
| 11/06/2024 | Free Chlorine | mg/L | 1.3200 | 0.2 - 5 | | |
| 11/06/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 11/06/2024 | Temperature | C | 17.3000 | | 30 | |
| 11/06/2024 | Turbidity | NTU | 0.0500 | | 5 | |
| 11/06/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 11/06/2024 | Total Chlorine | mg/L | 1.4000 | | 5 | |
| 5/06/2024 | pH | | 8.0100 | | 6.5 - 8.5 | |
| 5/06/2024 | Free Chlorine | mg/L | 1.4600 | 0.2 - 5 | | |
| 5/06/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 5/06/2024 | Temperature | C | 17.1000 | | 30 | |
| 5/06/2024 | Turbidity | NTU | 0.0500 | | 5 | |
| 5/06/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 5/06/2024 | Total Chlorine | mg/L | 1.5100 | | 5 | |
| 28/05/2024 | pH | | 8.1400 | | 6.5 - 8.5 | |
| 28/05/2024 | Free Chlorine | mg/L | 1.1300 | 0.2 - 5 | | |
| 28/05/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 28/05/2024 | Temperature | C | 20.4000 | | 30 | |
| 28/05/2024 | Turbidity | NTU | 0.3200 | | 5 | |
| 28/05/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 28/05/2024 | Total Chlorine | mg/L | 1.2700 | | 5 | |
| 20/05/2024 | pH | | 7.3200 | | 6.5 - 8.5 | |
| 20/05/2024 | Free Chlorine | mg/L | 1.5300 | 0.2 - 5 | | |
| 20/05/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 20/05/2024 | Temperature | C | 18.5000 | | 30 | |
| 20/05/2024 | Turbidity | NTU | 0.1100 | | 5 | |
| 20/05/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 20/05/2024 | Total Chlorine | mg/L | 1.5300 | | 5 | |
| 15/05/2024 | pH | | 7.3000 | | 6.5 - 8.5 | ,Field result entered as provided |
| 15/05/2024 | Free Chlorine | mg/L | 1.4500 | 0.2 - 5 | | ,Field result entered as provided |
| 15/05/2024 | E. coli | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 15/05/2024 | Temperature | C | 22.4000 | | 30 | ,Field result entered as provided |
| 15/05/2024 | Turbidity | NTU | 0.0100 | | 5 | ,Field result entered as provided |
| 15/05/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 15/05/2024 | Total Chlorine | mg/L | 1.4300 | | 5 | ,Field result entered as provided |
| 8/05/2024 | pH | | 7.2000 | | 6.5 - 8.5 | |
| 8/05/2024 | Free Chlorine | mg/L | 1.1500 | 0.2 - 5 | | |
| 8/05/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 8/05/2024 | Temperature | C | 21.8000 | | 30 | |
| 8/05/2024 | Turbidity | NTU | 0.2700 | | 5 | |
| 8/05/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 8/05/2024 | Total Chlorine | mg/L | 1.1900 | | 5 | |
| 29/04/2024 | pH | | 7.7300 | | 6.5 - 8.5 | ,Field result entered as provided |
| 29/04/2024 | Free Chlorine | mg/L | 0.6800 | 0.2 - 5 | | ,Field result entered as provided |
| 29/04/2024 | E. coli | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 29/04/2024 | Temperature | C | 23.2000 | | 30 | ,Field result entered as provided |
| 29/04/2024 | Turbidity | NTU | 0.0800 | | 5 | ,Field result entered as provided |
| 29/04/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 29/04/2024 | Total Chlorine | mg/L | 0.6200 | | 5 | ,Field result entered as provided |
| 22/04/2024 | pH | | 7.7600 | | 6.5 - 8.5 | |

| | | | | | | |
|------------|-----------------|------------|---------|---------|-----------|-------------------------------------|
| 22/04/2024 | Free Chlorine | mg/L | 1.3300 | 0.2 - 5 | | |
| 22/04/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 22/04/2024 | Temperature | C | 23.1000 | | 30 | |
| 22/04/2024 | Turbidity | NTU | 0.0100 | | 5 | |
| 22/04/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 22/04/2024 | Total Chlorine | mg/L | 1.3400 | | 5 | |
| 17/04/2024 | pH | | 8.1000 | | 6.5 - 8.5 | |
| 17/04/2024 | Free Chlorine | mg/L | 1.2100 | 0.2 - 5 | | |
| 17/04/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 17/04/2024 | Temperature | C | 25.7000 | | 30 | |
| 17/04/2024 | Turbidity | NTU | 0.0000 | | 5 | |
| 17/04/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 17/04/2024 | Total Chlorine | mg/L | 1.2600 | | 5 | |
| 8/04/2024 | pH | | 8.1300 | | 6.5 - 8.5 | |
| 8/04/2024 | Free Chlorine | mg/L | 0.8200 | 0.2 - 5 | | |
| 8/04/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 8/04/2024 | Temperature | C | 25.6000 | | 30 | |
| 8/04/2024 | Turbidity | NTU | 0.0000 | | 5 | |
| 8/04/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 8/04/2024 | Total Chlorine | mg/L | 0.9000 | | 5 | |
| 3/04/2024 | pH | | 7.9100 | | 6.5 - 8.5 | |
| 3/04/2024 | Free Chlorine | mg/L | 1.8300 | 0.2 - 5 | | |
| 3/04/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 3/04/2024 | Temperature | C | 26.6000 | | 30 | |
| 3/04/2024 | Turbidity | NTU | 0.0000 | | 5 | |
| 3/04/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 3/04/2024 | Total Chlorine | mg/L | 1.9500 | | 5 | |
| 26/03/2024 | pH | | 7.9600 | | 6.5 - 8.5 | |
| 26/03/2024 | Free Chlorine | mg/L | 0.4000 | 0.2 - 5 | | |
| 26/03/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 26/03/2024 | Temperature | C | 26.9000 | | 30 | |
| 26/03/2024 | Turbidity | NTU | 0.3800 | | 5 | |
| 26/03/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 26/03/2024 | Total Chlorine | mg/L | 0.6300 | | 5 | |
| 18/03/2024 | pH | | 7.8300 | | 6.5 - 8.5 | ,Sample contains ice |
| 18/03/2024 | Free Chlorine | mg/L | 1.3700 | 0.2 - 5 | | ,Sample contains ice |
| 18/03/2024 | E. coli | mpn/100 mL | < 1 | 0 | | ,Sample contains ice |
| 18/03/2024 | Temperature | C | 27.5000 | | 30 | ,Sample contains ice |
| 18/03/2024 | Turbidity | NTU | 0.0400 | | 5 | ,Sample contains ice |
| 18/03/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | ,Sample contains ice |
| 18/03/2024 | Total Chlorine | mg/L | 1.4400 | | 5 | ,Sample contains ice |
| 11/03/2024 | pH | | 8.1200 | | 6.5 - 8.5 | |
| 11/03/2024 | Free Chlorine | mg/L | 1.1000 | 0.2 - 5 | | |
| 11/03/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 11/03/2024 | Temperature | C | 27.6000 | | 30 | |
| 11/03/2024 | Turbidity | NTU | 0.1700 | | 5 | |
| 11/03/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 11/03/2024 | Total Chlorine | mg/L | 1.1700 | | 5 | |
| 4/03/2024 | pH | | 8.0600 | | 6.5 - 8.5 | |
| 4/03/2024 | Free Chlorine | mg/L | 1.0500 | 0.2 - 5 | | |
| 4/03/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 4/03/2024 | Temperature | C | 27.1000 | | 30 | |
| 4/03/2024 | Turbidity | NTU | 0.0800 | | 5 | |
| 4/03/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 4/03/2024 | Total Chlorine | mg/L | 1.1500 | | 5 | |
| 26/02/2024 | pH | | 7.8500 | | 6.5 - 8.5 | |
| 26/02/2024 | Free Chlorine | mg/L | 0.9600 | 0.2 - 5 | | |
| 26/02/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 26/02/2024 | Temperature | C | 28.9000 | | 30 | |
| 26/02/2024 | Turbidity | NTU | 0.3900 | | 5 | |
| 26/02/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 26/02/2024 | Total Chlorine | mg/L | 1.0400 | | 5 | |
| 19/02/2024 | pH | | 7.9400 | | 6.5 - 8.5 | ,Site code not provided - enter 999 |
| 19/02/2024 | Free Chlorine | mg/L | 0.7100 | 0.2 - 5 | | ,Site code not provided - enter 999 |
| 19/02/2024 | E. coli | mpn/100 mL | < 1 | 0 | | ,Site code not provided - enter 999 |
| 19/02/2024 | Temperature | C | 28.3000 | | 30 | ,Site code not provided - enter 999 |
| 19/02/2024 | Turbidity | NTU | 0.4200 | | 5 | ,Site code not provided - enter 999 |
| 19/02/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | ,Site code not provided - enter 999 |
| 19/02/2024 | Total Chlorine | mg/L | 0.7800 | | 5 | ,Site code not provided - enter 999 |

| | | | | | | |
|------------|-----------------|------------|---------|---------|-----------|-----------------------------------|
| 12/02/2024 | pH | | 7.7200 | | 6.5 - 8.5 | |
| 12/02/2024 | Free Chlorine | mg/L | 1.1500 | 0.2 - 5 | | |
| 12/02/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 12/02/2024 | Temperature | C | 29.9000 | | 30 | |
| 12/02/2024 | Turbidity | NTU | 0.0300 | | 5 | |
| 12/02/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 12/02/2024 | Total Chlorine | mg/L | 1.1900 | | 5 | |
| 5/02/2024 | pH | | 7.6000 | | 6.5 - 8.5 | |
| 5/02/2024 | Free Chlorine | mg/L | 1.2400 | 0.2 - 5 | | |
| 5/02/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 5/02/2024 | Temperature | C | 30.2000 | | 30 | |
| 5/02/2024 | Turbidity | NTU | 0.2800 | | 5 | |
| 5/02/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 5/02/2024 | Total Chlorine | mg/L | 1.2600 | | 5 | |
| 29/01/2024 | pH | | 7.8700 | | 6.5 - 8.5 | ,Field result entered as provided |
| 29/01/2024 | Free Chlorine | mg/L | 1.4500 | 0.2 - 5 | | ,Field result entered as provided |
| 29/01/2024 | E. coli | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 29/01/2024 | Temperature | C | 29.9000 | | 30 | ,Field result entered as provided |
| 29/01/2024 | Turbidity | NTU | 0.2900 | | 5 | ,Field result entered as provided |
| 29/01/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 29/01/2024 | Total Chlorine | mg/L | 1.4100 | | 5 | ,Field result entered as provided |
| 22/01/2024 | pH | | 8.0500 | | 6.5 - 8.5 | |
| 22/01/2024 | Free Chlorine | mg/L | 0.2000 | 0.2 - 5 | | |
| 22/01/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 22/01/2024 | Temperature | C | 27.9000 | | 30 | |
| 22/01/2024 | Turbidity | NTU | 0.7100 | | 5 | |
| 22/01/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 22/01/2024 | Total Chlorine | mg/L | 0.3200 | | 5 | |
| 15/01/2024 | pH | | 7.9500 | | 6.5 - 8.5 | ,Field result entered as provided |
| 15/01/2024 | Free Chlorine | mg/L | 1.1600 | 0.2 - 5 | | ,Field result entered as provided |
| 15/01/2024 | E. coli | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 15/01/2024 | Temperature | C | 28.7000 | | 30 | ,Field result entered as provided |
| 15/01/2024 | Turbidity | NTU | 0.1300 | | 5 | ,Field result entered as provided |
| 15/01/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 15/01/2024 | Total Chlorine | mg/L | 1.1200 | | 5 | ,Field result entered as provided |
| 8/01/2024 | pH | | 8.0900 | | 6.5 - 8.5 | ,Field result entered as provided |
| 8/01/2024 | Free Chlorine | mg/L | 1.6800 | 0.2 - 5 | | ,Field result entered as provided |
| 8/01/2024 | E. coli | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 8/01/2024 | Temperature | C | 29.3000 | | 30 | ,Field result entered as provided |
| 8/01/2024 | Turbidity | NTU | 0.1000 | | 5 | ,Field result entered as provided |
| 8/01/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | ,Field result entered as provided |
| 8/01/2024 | Total Chlorine | mg/L | 1.6100 | | 5 | ,Field result entered as provided |
| 2/01/2024 | pH | | 8.1100 | | 6.5 - 8.5 | |
| 2/01/2024 | Free Chlorine | mg/L | 1.4300 | 0.2 - 5 | | |
| 2/01/2024 | E. coli | mpn/100 mL | < 1 | 0 | | |
| 2/01/2024 | Temperature | C | 29.2000 | | 30 | |
| 2/01/2024 | Turbidity | NTU | 0.2700 | | 5 | |
| 2/01/2024 | Total Coliforms | mpn/100 mL | < 1 | 0 | | |
| 2/01/2024 | Total Chlorine | mg/L | 1.4700 | | 5 | |