

Mendooran Water Supply - Microbiological Test Results
(from the NSW Drinking Water Database)

Sample Collection		ADWG Guideline			ADWG Guideline Values	
Date	Tested Parameter	Units	Test Result	Values Health	Aesthetic	Laboratory Comments
29/07/2024	pH		8.2200		6.5 - 8.5	
29/07/2024	Free Chlorine	mg/L	2.3300	0.2 - 5		
29/07/2024	E. coli	mpn/100 mL	< 1	0		
29/07/2024	Temperature	C	14.8000		30	
29/07/2024	Turbidity	NTU	0.0600		5	
29/07/2024	Total Coliforms	mpn/100 mL	< 1	0		
29/07/2024	Total Chlorine	mg/L	2.3700		5	
15/07/2024	pH		8.1800		6.5 - 8.5	,Field result entered as provided
15/07/2024	Free Chlorine	mg/L	2.6900	0.2 - 5		,Field result entered as provided
15/07/2024	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
15/07/2024	Temperature	C	12.4000		30	,Field result entered as provided
15/07/2024	Turbidity	NTU	0.0000		5	,Field result entered as provided
15/07/2024	Total Coliforms	mpn/100 mL	< 1	0		,Field result entered as provided
15/07/2024	Total Chlorine	mg/L	2.6000		5	,Field result entered as provided
1/07/2024	pH		8.1600		6.5 - 8.5	
1/07/2024	Free Chlorine	mg/L	2.2700	0.2 - 5		
1/07/2024	E. coli	mpn/100 mL	< 1	0		
1/07/2024	Temperature	C	12.7000		30	
1/07/2024	Turbidity	NTU	0.2300		5	
1/07/2024	Total Coliforms	mpn/100 mL	< 1	0		
1/07/2024	Total Chlorine	mg/L	2.5000		5	
17/06/2024	pH		8.1800		6.5 - 8.5	
17/06/2024	Free Chlorine	mg/L	2.7400	0.2 - 5		
17/06/2024	E. coli	mpn/100 mL	< 1	0		
17/06/2024	Temperature	C	15.4000		30	
17/06/2024	Turbidity	NTU	0.1000		5	
17/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
17/06/2024	Total Chlorine	mg/L	2.9100		5	
5/06/2024	pH		8.2000		6.5 - 8.5	
5/06/2024	Free Chlorine	mg/L	3.4900	0.2 - 5		
5/06/2024	E. coli	mpn/100 mL	< 1	0		
5/06/2024	Temperature	C	15.1000		30	
5/06/2024	Turbidity	NTU	1.0000		5	
5/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
5/06/2024	Total Chlorine	mg/L	3.7000		5	
20/05/2024	pH		8.2100		6.5 - 8.5	
20/05/2024	Free Chlorine	mg/L	2.2300	0.2 - 5		
20/05/2024	E. coli	mpn/100 mL	< 1	0		
20/05/2024	Temperature	C	15.3000		30	
20/05/2024	Turbidity	NTU	0.8100		5	
20/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
20/05/2024	Total Chlorine	mg/L	2.2300		5	
8/05/2024	Total Chlorine	mg/L	3.2800		5	
8/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
8/05/2024	Turbidity	NTU	0.2500		5	
8/05/2024	Temperature	C	19.7000		30	
8/05/2024	E. coli	mpn/100 mL	< 1	0		
8/05/2024	Free Chlorine	mg/L	2.9800	0.2 - 5		
8/05/2024	pH		7.5500		6.5 - 8.5	
22/04/2024	pH		8.2000		6.5 - 8.5	,Field result entered as provided
22/04/2024	Free Chlorine	mg/L	4.0900	0.2 - 5		,Field result entered as provided
22/04/2024	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
22/04/2024	Temperature	C	19.3000		30	,Field result entered as provided
22/04/2024	Turbidity	NTU	0.5100		5	,Field result entered as provided
22/04/2024	Total Coliforms	mpn/100 mL	< 1	0		,Field result entered as provided
22/04/2024	Total Chlorine	mg/L	4.2800		5	,Field result entered as provided
8/04/2024	pH		8.2000		6.5 - 8.5	
8/04/2024	Free Chlorine	mg/L	2.9300	0.2 - 5		
8/04/2024	E. coli	mpn/100 mL	< 1	0		
8/04/2024	Temperature	C	22.5000		30	
8/04/2024	Turbidity	NTU	0.8000		5	
8/04/2024	Total Coliforms	mpn/100 mL	< 1	0		
8/04/2024	Total Chlorine	mg/L	3.1000		5	
26/03/2024	pH		7.5800		6.5 - 8.5	
26/03/2024	Free Chlorine	mg/L	0.9600	0.2 - 5		
26/03/2024	E. coli	mpn/100 mL	< 1	0		
26/03/2024	Temperature	C	27.6000		30	
26/03/2024	Turbidity	NTU	0.7600		5	
26/03/2024	Total Coliforms	mpn/100 mL	< 1	0		
26/03/2024	Total Chlorine	mg/L	1.2200		5	
11/03/2024	pH		8.2000		6.5 - 8.5	
11/03/2024	Free Chlorine	mg/L	0.6700	0.2 - 5		
11/03/2024	E. coli	mpn/100 mL	< 1	0		
11/03/2024	Temperature	C	28.2000		30	

11/03/2024	Turbidity	NTU	0.5900		5	
11/03/2024	Total Coliforms	mpn/100 mL	< 1	0		
11/03/2024	Total Chlorine	mg/L	0.7900		5	
26/02/2024	pH		8.4200		6.5 - 8.5	
26/02/2024	Free Chlorine	mg/L	2.8400	0.2 - 5		
26/02/2024	E. coli	mpn/100 mL	< 1	0		
26/02/2024	Temperature	C	26.5000		30	
26/02/2024	Turbidity	NTU	0.0800		5	
26/02/2024	Total Coliforms	mpn/100 mL	< 1	0		
26/02/2024	Total Chlorine	mg/L	2.9100		5	
12/02/2024	pH		8.1700		6.5 - 8.5	
12/02/2024	Free Chlorine	mg/L	0.0200	0.2 - 5		
12/02/2024	E. coli	mpn/100 mL	< 1	0		
12/02/2024	Temperature	C	29.3000		30	
12/02/2024	Turbidity	NTU	0.1400		5	
12/02/2024	Total Coliforms	mpn/100 mL	< 1	0		
12/02/2024	Total Chlorine	mg/L	0.0800		5	