Coolah Water Supply - Microbiological Test Results (from the NSW Drinking Water Database)

Sample Collection Date	Tested Parameter	Unit	Test Result	Australian Drinking Water Guidelines Value	Laboratory Comments
24/02/2020	E. coli	mpn/100 mL	< 1	0	
24/02/2020	Free Chlorine	mg/L	1.6400	0.2 - 5	
24/02/2020	pH		7.4600	6.5 - 8.5	
24/02/2020	Temperature	C	23.6000	30	
24/02/2020	Total Chlorine	mg/L	1.7000	5	
24/02/2020	Total Coliforms	mpn/100 mL	< 1	0	
24/02/2020	Turbidity	NTU	0.5900	5	
17/02/2020	E. coli	mpn/100 mL	< 1	0	
17/02/2020	Free Chlorine	mg/L	1.3400	0.2 - 5	
17/02/2020	pH		7.9300	6.5 - 8.5	
17/02/2020	Total Chlorine	mg/L	1.3800	5	
17/02/2020	Total Coliforms	mpn/100 mL	< 1	0	
17/02/2020	Turbidity	NTU	0.2900	5	
11/02/2020	E. coli	mpn/100 mL	< 1	0	
11/02/2020	Free Chlorine	mg/L	0.7900	0.2 - 5	
11/02/2020	pH		7.5600	6.5 - 8.5	
11/02/2020	Total Chlorine	mg/L	0.8000	5	
11/02/2020	Total Coliforms	mpn/100 mL	< 1	0	
11/02/2020	Turbidity	NTU	0.2300	5	
4/02/2020	E. coli	mpn/100 mL	< 1	0	
4/02/2020	Free Chlorine	mg/L	1.4100	0.2 - 5	
4/02/2020	pH		8.0000	6.5 - 8.5	
4/02/2020	Total Chlorine	mg/L	1.4400	5	
4/02/2020	Total Coliforms	mpn/100 mL	< 1	0	
4/02/2020	Turbidity	NTU	0.3000	5	
28/01/2020	E. coli	mpn/100 mL	< 1	0	
28/01/2020	Free Chlorine	mg/L	1.3800	0.2 - 5	
28/01/2020	pH		7.5300	6.5 - 8.5	
28/01/2020	Total Chlorine	mg/L	1.4100	5	
28/01/2020	Total Coliforms	mpn/100 mL	< 1	0	
28/01/2020	Turbidity	NTU	2.1500	5	
21/01/2020	E. coli	mpn/100 mL	< 1	0	
21/01/2020	Free Chlorine	mg/L	1.6300	0.2 - 5	
21/01/2020	pH		7.9100	6.5 - 8.5	
21/01/2020	Total Chlorine	mg/L	1.6400	5	
21/01/2020	Total Coliforms	mpn/100 mL	< 1	0	
21/01/2020	Turbidity	NTU	0.7600	5	
14/01/2020	E. coli	mpn/100 mL	< 1	0	
14/01/2020	Free Chlorine	mg/L	1.4800	0.2 - 5	
14/01/2020	pH		7.8300	6.5 - 8.5	
14/01/2020	Total Chlorine	mg/L	1.5000	5	
14/01/2020	Total Coliforms	mpn/100 mL	< 1	0	
14/01/2020	Turbidity	NTU	0.8200	5	
14/01/2020	E. coli	mpn/100 mL	< 1	0	
14/01/2020	Free Chlorine	mg/L	1.5300	0.2 - 5	
14/01/2020	pH		7.7700	6.5 - 8.5	
14/01/2020	Total Chlorine	mg/L	1.5500	5	
14/01/2020	Total Coliforms	mpn/100 mL	< 1	0	
14/01/2020	Turbidity	NTU	0.1100	5	
6/01/2020	E. coli	mpn/100 mL	< 1	0	
6/01/2020	Free Chlorine	mg/L	1.2900	0.2 - 5	
6/01/2020	pH		7.7000	6.5 - 8.5	
6/01/2020	Total Chlorine	mg/L	1.3300	5	
6/01/2020	Total Coliforms	mpn/100 mL	> 200	0	
6/01/2020	Turbidity	NTU	0.1300	5	
2/01/2020	E. coli	mpn/100 mL	< 1	0	
2/01/2020	Free Chlorine	mg/L	1.9400	0.2 - 5	
2/01/2020	pH		7.0700	6.5 - 8.5	
2/01/2020	Total Chlorine	mg/L	2.4700	5	
2/01/2020	Total Coliforms	mpn/100 mL	< 1	0	
2/01/2020	Turbidity	NTU	0.2300	5	
16/12/2019	E. coli	mpn/100 mL	< 1	0	
16/12/2019	Free Chlorine	mg/L	2.0500	0.2 - 5	
16/12/2019	pH		7.8900	6.5 - 8.5	
16/12/2019	Total Chlorine	mg/L	2.1300	5	
16/12/2019	Total Coliforms	mpn/100 mL	< 1	0	
16/12/2019	Turbidity	NTU	0.4500	5	
9/12/2019	E. coli	mpn/100 mL	< 1	0	

9/12/2019	Free Chlorine	mg/L	1.5400	0.2 - 5	
9/12/2019	pH		7.6200	6.5 - 8.5	
9/12/2019	Total Chlorine	mg/L	1.6700	5	
9/12/2019	Total Coliforms	mpn/100 mL	< 1	0	
9/12/2019	Turbidity	NTU	0.2400	5	
3/12/2019	E. coli	mpn/100 mL	< 1	0	
3/12/2019	Free Chlorine	mg/L	1.7600	0.2 - 5	
3/12/2019	pH		7.6400	6.5 - 8.5	
3/12/2019	Total Chlorine	mg/L	1.8600	5	
3/12/2019	Total Coliforms	mpn/100 mL	< 1	0	
3/12/2019	Turbidity	NTU	0.3000	5	
25/11/2019	E. coli	mpn/100 mL	< 1	0	
25/11/2019	Free Chlorine	mg/L	1.7500	0.2 - 5	
25/11/2019	pH		7.6300	6.5 - 8.5	
25/11/2019	Total Chlorine	mg/L	1.8200	5	
25/11/2019	Total Coliforms	mpn/100 mL	< 1	0	
25/11/2019	Turbidity	NTU	0.2300	5	
18/11/2019	E. coli	mpn/100 mL	< 1	0	
18/11/2019	Free Chlorine	mg/L	1.2300	0.2 - 5	
18/11/2019	pH		7.5800	6.5 - 8.5	
18/11/2019	Total Chlorine	mg/L	1.3900	5	
18/11/2019	Total Coliforms	mpn/100 mL	< 1	0	
18/11/2019	Turbidity	NTU	0.6900	5	
11/11/2019	E. coli	mpn/100 mL	< 1	0	
11/11/2019	Free Chlorine	mg/L	1.7000	0.2 - 5	
11/11/2019	pH		7.5700	6.5 - 8.5	
11/11/2019	Temperature	C	26.6000	30	
11/11/2019	Total Chlorine	mg/L	1.6200	5	
11/11/2019	Total Coliforms	mpn/100 mL	< 1	0	
11/11/2019	Turbidity	NTU	0.2400	5	
4/11/2019	E. coli	mpn/100 mL	< 1	0	
4/11/2019	Free Chlorine	mg/L	1.6500	0.2 - 5	
4/11/2019	pH		7.5800	6.5 - 8.5	
4/11/2019	Total Chlorine	mg/L	2.8000	5	
4/11/2019	Total Coliforms	mpn/100 mL	< 1	0	
4/11/2019	Turbidity	NTU	0.5800	5	
29/10/2019	E. coli	mpn/100 mL	< 1	0	
29/10/2019	Free Chlorine	mg/L	1.7800	0.2 - 5	
29/10/2019	pH		7.6600	6.5 - 8.5	
29/10/2019	Total Chlorine	mg/L	1.8900	5	
29/10/2019	Total Coliforms	mpn/100 mL	< 1	0	
29/10/2019	Turbidity	NTU	0.6300	5	
22/10/2019	E. coli	mpn/100 mL	< 1	0	
22/10/2019	Free Chlorine	mg/L	1.6400	0.2 - 5	
22/10/2019	pH		7.7700	6.5 - 8.5	
22/10/2019	Total Chlorine	mg/L	1.6600	5	
22/10/2019	Total Coliforms	mpn/100 mL	< 1	0	
22/10/2019	Turbidity	NTU	0.5100	5	
15/10/2019	E. coli	mpn/100 mL	< 1	0	
15/10/2019	Total Coliforms	mpn/100 mL	< 1	0	
8/10/2019	E. coli	mpn/100 mL	< 1	0	
8/10/2019	Free Chlorine	mg/L	1.1800	0.2 - 5	
8/10/2019	pH		7.6800	6.5 - 8.5	
8/10/2019	Total Chlorine	mg/L	1.4600	5	
8/10/2019	Total Coliforms	mpn/100 mL	< 1	0	
8/10/2019	Turbidity	NTU	0.3000	5	