

Mendooran Water Supply - Microbiological Test Results
(From the NSW Drinking Water Database)

Sample Collection Date	Tested Parameter	Units	Test Result	Australian Drinking Water Guidelines Value - Health	Australian Drinking Water Guidelines Value - Aesthetic	Laboratory Comments
18/08/2025	E. coli	mpn/100 mL	< 1	0		
18/08/2025	Free Chlorine	mg/L	1.45	0.2 - 5		
18/08/2025	pH		8.15		6.5 - 8.5	
18/08/2025	Temperature	C	14.2		30	
18/08/2025	Total Chlorine	mg/L	1.85	5		
18/08/2025	Total Coliforms	mpn/100 mL	< 1		0	
18/08/2025	Turbidity	NTU	0.38		5	
4/08/2025	E. coli	mpn/100 mL	< 1	0		
4/08/2025	Free Chlorine	mg/L	0.62	0.2 - 5		
4/08/2025	pH		8.17		6.5 - 8.5	
4/08/2025	Temperature	C	13		30	
4/08/2025	Total Chlorine	mg/L	1.24	5		
4/08/2025	Total Coliforms	mpn/100 mL	< 1		0	
4/08/2025	Turbidity	NTU	0.03		5	
21/07/2025	E. coli	mpn/100 mL	< 1	0		
21/07/2025	Free Chlorine	mg/L	0.88	0.2 - 5		
21/07/2025	pH		8.13		6.5 - 8.5	
21/07/2025	Temperature	C	10.5		30	
21/07/2025	Total Chlorine	mg/L	1.62	5		
21/07/2025	Total Coliforms	mpn/100 mL	< 1		0	
21/07/2025	Turbidity	NTU	0.13		5	
7/07/2025	E. coli	mpn/100 mL	< 1	0		
7/07/2025	Free Chlorine	mg/L	1.78	0.2 - 5		
7/07/2025	pH		8.02		6.5 - 8.5	
7/07/2025	Temperature	C	12.5		30	
7/07/2025	Total Chlorine	mg/L	2.54	5		
7/07/2025	Total Coliforms	mpn/100 mL	< 1		0	
7/07/2025	Turbidity	NTU	0.02		5	
23/06/2025	E. coli	mpn/100 mL	< 1	0		
23/06/2025	Free Chlorine	mg/L	4.6	0.2 - 5		
23/06/2025	pH		8.22		6.5 - 8.5	
23/06/2025	Temperature	C	12.4		30	
23/06/2025	Total Chlorine	mg/L	6.06	5		
23/06/2025	Total Coliforms	mpn/100 mL	< 1		0	
23/06/2025	Turbidity	NTU	0.07		5	
16/06/2025	E. coli	mpn/100 mL	< 1	0		
16/06/2025	Free Chlorine	mg/L	4.18	0.2 - 5		
16/06/2025	pH		8.19		6.5 - 8.5	
16/06/2025	Temperature	C	12.8		30	
16/06/2025	Total Chlorine	mg/L	4.27	5		
16/06/2025	Total Coliforms	mpn/100 mL	< 1		0	
16/06/2025	Turbidity	NTU	0.11		5	

2/06/2025	E. coli	mpn/100 mL	< 1	0		
2/06/2025	Free Chlorine	mg/L	1.46	0.2 - 5		
2/06/2025	pH		8.18		6.5 - 8.5	
2/06/2025	Temperature	C	16.3		30	
2/06/2025	Total Chlorine	mg/L	1.51	5		
2/06/2025	Total Coliforms	mpn/100 mL	< 1		0	
2/06/2025	Turbidity	NTU	0		5	
26/05/2025	E. coli	mpn/100 mL	< 1	0		
26/05/2025	Free Chlorine	mg/L	0.22	0.2 - 5		
26/05/2025	pH		8.2		6.5 - 8.5	
26/05/2025	Temperature	C	16.6		30	
26/05/2025	Total Chlorine	mg/L	1.23	5		
26/05/2025	Total Coliforms	mpn/100 mL	< 1		0	
26/05/2025	Turbidity	NTU	0.29		5	
12/05/2025	E. coli	mpn/100 mL	< 1	0		
12/05/2025	Free Chlorine	mg/L	0.01	0.2 - 5		
12/05/2025	pH		8.18		6.5 - 8.5	
12/05/2025	Temperature	C	20.2		30	
12/05/2025	Total Chlorine	mg/L	0.05	5		
12/05/2025	Total Coliforms	mpn/100 mL	< 1		0	
12/05/2025	Turbidity	NTU	0.04		5	
28/04/2025	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
28/04/2025	Free Chlorine	mg/L	0.03	0.2 - 5		,Field result entered as provided
28/04/2025	pH		8.2		6.5 - 8.5	,Field result entered as provided
28/04/2025	Temperature	C	20.6		30	,Field result entered as provided
28/04/2025	Total Chlorine	mg/L	0.16	5		,Field result entered as provided
28/04/2025	Total Coliforms	mpn/100 mL	< 1		0	,Field result entered as provided
28/04/2025	Turbidity	NTU	0.02		5	,Field result entered as provided
15/04/2025	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
15/04/2025	Free Chlorine	mg/L	1.7	0.2 - 5		,Field result entered as provided
15/04/2025	pH		8.21		6.5 - 8.5	,Field result entered as provided
15/04/2025	Temperature	C	24.7		30	,Field result entered as provided
15/04/2025	Total Chlorine	mg/L	1.91	5		,Field result entered as provided
15/04/2025	Total Coliforms	mpn/100 mL	< 1		0	,Field result entered as provided
15/04/2025	Turbidity	NTU	0.64		5	,Field result entered as provided

[illegible]

