

Kenebri Water Supply - Microbiological Test Results (From the NSW Drinking Water Database)

Sample Collection						
Date	Tested Parameter	Units	Test Results	ADWG Guideline Values Health	ADWG Guideline Values Aesthetic	Laboratory Comments
5/02/2025	E. coli	mpn/100 mL	< 1	0		
5/02/2025	Free Chlorine	mg/L	1.75	0.2 - 5		
5/02/2025	pH		7.52		6.5 - 8.5	
5/02/2025	Temperature	C	30		30	
5/02/2025	Total Chlorine	mg/L	1.75	5		
5/02/2025	Total Coliforms	mpn/100 mL	< 1	0		
5/02/2025	Turbidity	NTU	0.05		5	
8/01/2025	E. coli	mpn/100 mL	< 1	0		
8/01/2025	Free Chlorine	mg/L	1.8	0.2 - 5		
8/01/2025	pH		7.52		6.5 - 8.5	
8/01/2025	Temperature	C	28.4		30	
8/01/2025	Total Chlorine	mg/L	1.8	5		
8/01/2025	Total Coliforms	mpn/100 mL	< 1	0		
8/01/2025	Turbidity	NTU	0.88		5	
4/12/2024	E. coli	mpn/100 mL	< 1	0		
4/12/2024	Free Chlorine	mg/L	0.45	0.2 - 5		
4/12/2024	pH		7.95		6.5 - 8.5	
4/12/2024	Temperature	C	25.9		30	
4/12/2024	Total Chlorine	mg/L	0.71	5		
4/12/2024	Total Coliforms	mpn/100 mL	< 1	0		
4/12/2024	Turbidity	NTU	0.18		5	
13/11/2024	E. coli	mpn/100 mL	< 1	0		
13/11/2024	Free Chlorine	mg/L	1.82	0.2 - 5		
13/11/2024	pH		8.09		6.5 - 8.5	
13/11/2024	Temperature	C	26.8		30	
13/11/2024	Total Chlorine	mg/L	1.78	5		
13/11/2024	Total Coliforms	mpn/100 mL	< 1	0		
13/11/2024	Turbidity	NTU	0.21		5	
9/10/2024	E. coli	mpn/100 mL	< 1	0		
9/10/2024	Free Chlorine	mg/L	1.21	0.2 - 5		
9/10/2024	pH		7.93		6.5 - 8.5	
9/10/2024	Temperature	C	20.9		30	
9/10/2024	Total Chlorine	mg/L	1.17	5		
9/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
9/10/2024	Turbidity	NTU	0.2		5	
3/09/2024	E. coli	mpn/100 mL	< 1	0		
3/09/2024	Free Chlorine	mg/L	1.37	0.2 - 5		
3/09/2024	pH		7.88		6.5 - 8.5	
3/09/2024	Temperature	C	17.5		30	
3/09/2024	Total Chlorine	mg/L	1.4	5		
3/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
3/09/2024	Turbidity	NTU	1.59		5	