Page : 2 of 2 Work Order : WN2304136

Client : WARRUMBUNGLE SHIRE COUNCIL

Project : Coolah STP - EPL 4445

General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key: CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.

LOR = Limit of reporting

- ^ = This result is computed from individual analyte detections at or above the level of reporting
- ø = ALS is not NATA accredited for these tests.
- ~ = Indicates an estimated value.

Analytical Results

Sub-Matrix: WATER (Matrix: WATER)					 	
Sampling date / time				30-Mar-2023 00:00	 	
Compound	CAS Number	LOR	Unit	WN2304136-001	 	
				Result	 	
EA005: pH						
pH Value		0.01	pH Unit	9.35	 	
EA025: Total Suspended Solids dried at	t 104 ± 2°C					
Suspended Solids (SS)		1	mg/L	108	 	
EK062A: Total Nitrogen as N						
Total Nitrogen as N		0.1	mg/L	18.1	 	
EK067A: Total Phosphorus as P						
Total Phosphorus as P		0.05	mg/L	1.85	 	
EP021: Total Oil and Grease						
Total Oil and Grease		2	mg/L	2	 	
EP030.WN: Biochemical Oxygen Dema	nd (BOD)					
Biochemical Oxygen Demand		2	mg/L	30	 	



Page : 2 of 2 Work Order : WN2211436

Client : WARRUMBUNGLE SHIRE COUNCIL

Project : Coolah STP - EPL 4445

ALS

General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key: CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.

LOR = Limit of reporting

- ^ = This result is computed from individual analyte detections at or above the level of reporting
- ø = ALS is not NATA accredited for these tests.
- ~ = Indicates an estimated value.

Analytical Results

Sub-Matrix: WATER (Matrix: WATER)			Sample ID	Effluent Coolah point 4	 	
Sampling date / time				13-Sep-2022 13:00	 	
Compound	CAS Number	LOR	Unit	WN2211436-001	 	
				Result	 	
EA005: pH						
pH Value		0.01	pH Unit	9.07	 	
EA025: Total Suspended Solids dried	at 104 ± 2°C					
Suspended Solids (SS)		1	mg/L	82	 	
EK062A: Total Nitrogen as N						
Total Nitrogen as N		0.1	mg/L	11.1	 	
EK067A: Total Phosphorus as P						
Total Phosphorus as P		0.05	mg/L	3.20	 	
EP021: Total Oil and Grease						
Total Oil and Grease		2	mg/L	2	 	
EP030.WN: Biochemical Oxygen Den	nand (BOD)					
Biochemical Oxygen Demand		2	mg/L	44	 	